



## Inspection Report

KARL MOGENSEN

Customer ID: 2468

Certificate: 52-C-0035

Site: 001

NATURAL BRIDGE ZOO

NATURAL BRIDGE ZOOLOGICAL PARK

PO BOX 88

Type: ROUTINE INSPECTION

Date: 19 February 2014

NATURAL BRIDGE, VA 24578

3.75 (c)(2)

### HOUSING FACILITIES, GENERAL.

The concrete floor in the "mouse" building needs to be repaired. In the center primate enclosure a low spot has developed in the concrete flooring where water stands after the floor has been cleaned. The concrete has degraded in this area to the underlying gravelly surface which is so rough and uneven that the water cannot be swept or squeegeed away. The concrete has turned black in this area and does not respond to bleach indicating that the flooring can no longer be sanitized as required. Regular sanitization of indoor surfaces with which the primates come into contact is an important part of the disease control program. The area of the flooring that has become degraded must be repaired so that it can be properly cleaned and sanitized. Correct by 22 June 2014.

An exit interview was conducted with the owners.

Prepared By:

DORIS HACKWORTH, D V M

DORIS T HACKWORTH, D V M USDA, APHIS, Animal Care

Title:

VETERINARY MEDICAL OFFICER Inspector 2029

Date:

19 February 2014

Received By:

(b)(6),(b)(7)(c)

Date:

20 February 2014

Title: